

Vedanshi Fire Protection

Dealers and service Engg of the fire Extinguishers, Safety Product, Electrical, Chemical, Gas Bank & General Supplier

S.K.badgaiyan

Contact - +91-9302130056

Date: 26/03/2021

To,
The Principal,
Hitkarni Children Academy
Dumna, Jabalpur (M.P.)

ANNEXURE
Fire safety


Sub:-Fire Inspection Report

Dear Sir/Madam,

With reference to above our Fire Expert and his team visited your school regards to provision of fire safety required as per norms.

I was observed that the school is having ground floor as per fire safety norms. Our fire expert submitted the report and following are the recommendation for the school.


- 1) Provision for fire exits.
- 2) ABC type fire extinguisher
- 3) CO2 type fire extinguisher
- 4) Fire Hose reel
- 5) Smoke detectors
- 6) Fire Alarm
- 7) Fire Bucket with stand


Principal
Hitkarini Children Academy
Dumna Road, JABALPUR (M.P.)


Regards


For Vedanshi Fire Protection

Vedanshi Fire Protection


Proprietor

Plot No. 4, In front of Bhasanar Mandir, behind Dr. Bhattacharya, Ganga
Nagar, Garha, Jabalpur


Principal
Hitkarini Children Academy
Dumna Road, JABALPUR (M.P.)


Principal
Hitkarini Children Academy
Dumna Road, JABALPUR (M.P.)